

Questions and Answers #4

Are we expected to include the DEVICES AND EQUIPMENT for the following Scope of work or CONDUIT AND RACEWAYS only?

- Video Surveillance System
- Auditorium and Sound System
- Intrusion Detection System

The Video Surveillance, Assembly sound system is an empty conduit system.

Video surveillance: As noted on drawings for camera locations, conduit from locations to 2nd Floor Mechanical Room for future use.

Assembly sound system is an empty conduit system with ½" conduit with pull strings interconnecting the ceiling speakers, shown on sheet E2.11, and a ¾" conduits connecting the ceiling speakers to the 2nd Floor Mechanical Room and the terminal cabinet in the Supply Room.

Intrusion Detection: As noted on drawings sheet E5.3 and Specification Sections 13845 and 13860 (this system maybe reviewed if needed and deleted as a line item)