

**QUESTION 1:**

Several building section show 5/8" type "x" sheetrock over hihats attached to bottom of roof trusses however this is a fully sprinkled building and those areas have acoustical ceiling tile.

Is this to remain as noted right now basically a double ceiling?

**This is to remain.**

**QUESTION 2:**

Addendum 1 has clarification related to Main hall work and the heading above read

SEE BELOW

**NEW ALTERNATE QUARTERS** (inside the new City Hall Building)

**LANDLORD / CITY RESPONSIBILITIES**

**Design** - The Architectural firm for the new City Hall Complex -- LIVS Associates. Refer to set of drawings labeled DESIGN DEVELOPMENT dated June 11, 2021 with 93 sheets. The design of the AQ Post Office is included in the above set of drawings.

**Construction** - To construct a new City Hall building which includes a unit space building shell on the First Floor consisting of 1,576 net sq ft. The following systems are included in Landlord Work: Furnish and install:

Please confirm none of the work noted on addendum is to be done by GC. Noted work says "landlord/City responsibilities" Clarify is that in turn means is the GC to do the work? Please clarify.

**GC is responsible for the work under "Landlord/City responsibilities" .**

**QUESTION 3:** On several questions before it has been said that addensums will be issue in order to clarify questions but not further addensums have been issued and due date is coming up and it seems as if an extension shall be given in order to properly price any pending addendums.

**Landscape addendum will be issued next week. Any extension of the bid date is to be addressed by City representative.**